

**RESOLUTION NO 24-R-89**

**A RESOLUTION TO APPROVE POOL PUMP REPLACEMENT WWC**

WHEREAS, the Tinley Park-Park District is located in Cook & Will Counties of Illinois, and

WHEREAS, throughout the 2024 season, we had many issues with one of the current 30 HP pumps. The current pump that is recommended for replacement is original to the facility from 2002; and

WHEREAS, this pump is one of two pumps that create the flow for the lazy river; and

WHEREAS, staff recommends Thomas Pump Company, Inc. for 30 HP motor installation and replacement for an amount not to exceed \$8,000; and

WHEREAS, The Board of Commissioners of the Tinley Park-Park District finds that it is in the best interest of the District to approve the pool pump replacement for the water park to Thomas Pump Company Inc. for an amount not to exceed \$8,000.

NOW, THEREFORE, BE IT RESOLVED by the Commissioners of the TINLEY PARK-PARK DISTRICT as follows:

SECTION 1: The Preambles hereto are hereby made a part of, and an operative provision of, this Resolution as if fully restated herein.


SECTION 2: The Request attached hereto as Exhibit 1, and made a part hereof, is hereby approved.

SECTION 3: That this Resolution shall be in full force and effect on the date approved and passed by the Board of Commissioners of the TINLEY PARK-PARK DISTRICT.

Approved and passed this 18<sup>th</sup> day of December 2024.


AYES: 5  
NAYS: 0  
ABSENT: 0  
ABSTAIN: 0

TINLEY PARK-PARK DISTRICT



\_\_\_\_\_  
Marie Ryan  
President, Board of Park Commissioners

Attest:



\_\_\_\_\_  
Ashley Rubino  
Secretary, Board of Park Commissioners

EXHIBIT 1 RESOLUTION NO 24-R-89

**Thomas Pump Company, Inc.**

*Pump Engineers*



**Established 1920**

**Celebrating over 100 years of service**

**2301 E. Liberty St.  
Aurora, IL. 60502**

**Phone: (630) 851-9393  
Fax: (630) 851-9397**

[www.tpcoinc.com](http://www.tpcoinc.com)

September 3, 2024

Q-67358

Tinley Park - Park District  
8125 W. 171st Street

Attn: Tim Harvey

Ref: Slide Pump  
Outdoor Pool

Estimated cost to repair

1) 30HP motor 1800RPM TEFC -----\$ 2,354.00

1) Mechanical seal kit -----\$ 568.00

1) Shaft sleeve -----\$ 240.00

1) Bracket w/ epoxy coating (if required) -----\$ 491.00

Motor electric connections -----\$ 60.00

Uni-strut base SS -----\$ 450.00

Estimated labor and travel: 3 men -----\$ 3,000.00 - \$ 3,800.00

Above pricing includes all incoming freight

All new SS nuts, bolts, (1) stand and pump included in above

All items are stock at Thomas Pump

Motor is stock at WEG factory

Prices good for 45 days

**TERMS:** *Net 30 days from date of invoice, no retainable withheld, past due invoices will be subject to a monthly service charge of 1-1/2% per month on the outstanding balance. Price quoted specifically excludes all federal, state and/or local taxes/permits. Should collections be necessary to satisfy the amount outstanding and due to Thomas Pump Company, all expenses incurred by Thomas Pump Company (as a result of this collection) including and not limited to attorney fees, court costs and interest will be paid by customer. By issuing a purchase order to Thomas Pump Company, the customer acknowledges and agrees to Thomas Pump Company's terms of payment, which is documented and included in our quotation.*

**SALES TAX:** *If this is a taxable job, please indicate on purchase order or submit tax-exempt form/number. If a tax exempt Form/number is not provided, Illinois state sales tax will be added at a rate of 8.25%.*

**CANCELLATION**

**POLICY:** *0-2 weeks after receipt of purchase order: 15% of purchase price, 2-4 weeks: 35%, 4-6 weeks: 50%, 6-8 Weeks: 75%, 8+ weeks: 100% of purchase price – payments in full.*

*Errors and Omissions: This quotation is for the items listed or stated above. No other items should be assumed or implied as being provided.*

Yours Very Truly

Thomas Pump Company, Inc.

**Robert A. McCue**

**Thomas Pump Co., Inc.**